

A TR Engineering Inc.

9929 SW 206th CT
Vashon WA. 98070
(206) 463-5735

3/11/99

TO:

Masonry Heater Association / WSCPA
c/o Lopez Quarries Masonry Heaters / Firecrest Fireplace Corp.
111 Barbara Lane
Everett WA. 98203

Attention Mr. Jerry Frisch
Subject: Masonry Heater Stabilization / Supplemental to report dated 7/20/98

Dear Jerry,

I have revised the previous calculations to include the new Uniform Building Code lateral coefficients. I have also modified my previous calculations to include the resisting effect of the structures' dead load. As you can see in the attached calculation sheet the resistance to overturning is greater than the overturning caused by the lateral force, with a factor of safety (FS) greater than 1.0 in all cases. This satisfies the code requirement for stability. Although stability of the stoves is shown, I would like to suggest that we still use the details shown on drawings M-4 and M-5 with these modifications: (1) use a 1/4" flat plate in lieu of the previous channel and (2) use 1/4" diameter rods instead of 3/8" diameter. This will provide an extra factor of safety against workmanship and varying unit dead load weights for each stove type.

If you have any questions regarding this information, please feel free to call.

Sincerely,

A.T. Rack

Arthur T. Rack P.E.
President



ATR Engineering Inc.
Consulting Engineer
9929 SW 206th Ct.
Vashon, WA 98070

phone: (206) 463-5735

PROJECT


MASONRY HEATER ASSOCIATION

MASONRY STONE STABILITY

Sheet No.

M-1

Date 7/20/98



$$M_{OT} = V \times \frac{H}{2}$$

$$M_R = DL \times \frac{W}{2}$$

$$T = \frac{M_{OT} - M_R}{W}$$

WHERE $V = .2W$
SEISMIC ZONE 4
NON-BUILDING STRUCTURE

New
M2

file: masonOT

For **Masonry Heater Association I WSCPA**
c/o Lopez Quarries Masonry Heaters / Firecrest Fireplace Copr.
111 Barbara Lane
Everett WA 98203

Masonry Stove Types
 1. **Russian** Multi-Flue
 2. **German Austrian**
 3. Finnish
 4. Swedish
 5. Small Grundofen

STABILITY CHECK

Mark	Firebox Weights (lbs)	Height (ft)	Width (inches)	Length (inches)	Lateral Seismic (lbs) v=% of Gravity 0.252	Mot Overturning Moment #-A	Mr Resisting Moment #-ft	Factor of Safety FS= Mr/Mot
Type 1	20,000	7.25	36	72	5,040	18,270	30,000	1.64
Type 2	14,000	7.25	32	64	3,528	12,789	18,667	1.46
Type 3	12,500	7.25	36	48	3,150	11,419	18,750	1.64
Type 4	11,000	7.25	26	44	2,772	10,049	11,917	1.19
Type 5	9,000	5.00	24	34	2,268	5,670	9 . m	1.59

Per 1997 Uniform Building Code / Seismic Zone 3
 Lateral per 1629.6.8 for Non Building Structural Systems
 Per 1634.3 for Rigid Structures
 $V = 0.7 \times C_a \times I \times W$ where $C_a = 0.36$ / $I = 1.0$
 $V = 0.252 W$
 Overturning and Stability Requirements Per 1605.2.2

Revised to (4) 1/4" rods & 1/4" plate

, R Engineering Inc.
Consulting Engineer
9929 SW 206th Ct.
Vashon, WA 98070

phone: (206) 463-5735

PROJECT

Masonry Heater Association

MASONRY STOVE STABILITY

Sheet No.

M-3

Date 7/20/98

EMBEDMENT OF 3/8" ϕ INTO PUMC PAD
Assume $f_c = 2500$ psi min.


MINIMUM LOAD TO DEVELOP = 2500* / ROD.
 $L_d = 12d = 4 1/2"$ min. $\Rightarrow$ implies 6" TK
PAD.

MIN EDGE DISTANCE 5d or 4" min.
 $5d = 1.875"$ USE 4" min

EPOXY GROUT

3/8" $\phi = 6580 \# \div 4 = 1645 \# / \text{ROD} = 3 \text{ REQ'D}$
1/2" $\phi = 12015 \# \div 4 = 3003 \# / \text{ROD} = 2 \text{ REQ'D}$

ALTERNATE MULTI SET ANCHOR TM RED HEAD



3/8" $\phi = 3300 \div 4 = 825$
1/2" $\phi = 5450 \div 4 = 1362$
5/8" $\phi = 7000 \div 4 = 1750 \#$

N
REQ'D
6
4
3

1 3/8 dia 3/8
1 3/4 for 1/2
2 1/4 for 5/8

SHEAR Across HORIZONTAL PLATE

Assume Compression @ 50 psi
FOR 1. $V = 4000 \#$

TOTAL AREA = $2(36" + 72") \times 1/4" = 3.625" = 783 \text{ in}^2$

COEFFICIENT OF FRICTION Masonry / MASONRY = 0.5 TO 0.7
TOTAL RESISTANCE = $0.5 \times 783 \times 50 \text{ psi} = 19,575 \# > 4000 \#$

ATR Engineering inc.
Consulting Engineer
9929 SW 206th Ct.
Vashon, WA 96070

PROJECT


Sheet No.

phone: (206) 463-5735

MASONRY HEATER ASSOCIATION
MASONRY STOVE STABILITY

M-4

Date 7/20/98



PLAN / ROD LAYOUT

Revised to
4- 1/4" ROD S

W/ 1/4" FLAT PLATE ON TOP

See COVER LETTER- 3/11/99

ATR Engineering Inc.
Consulting Engineer
9929 SW 206th Ct.
Vashon, WA 98070

phone: (206) 463-5735

PROJECT


MASONRY HEATER ASSOCIATION

MASONRY STOVE STABILITY

Sheet No.

M-5

Date 7/20/98



SECTION @ TENSION ROAD
NTS

REVISED 3/11/99

JR Engineering Inc.
Consulting Engineer
9929 SW 206th Ct.
Vashon, WA 98070

phone: (206) 463-5735

PROJECT

Masonry Heaters Association


TORQUE CALCULATIONS

Sheet No.

MC


Date 7/20/98

FREE BODY DIAGRAM



SEE CALCULATIONS

THEN



TORQUE ON RODS

$$\begin{aligned} @ 50 \text{ psi} \\ \text{WITH } A = 783 \text{ in}^2 \end{aligned} \left\{ \begin{aligned} R &= 19,575 \# > 4000 \# \\ \text{REDUCTION FACTOR} &= \frac{4000 \text{ REQ'D}}{19,575 \text{ PROVIDED}} = 0.204 \end{aligned} \right.$$

$$\text{THEN } 50 \text{ psi} \times 0.204 = \text{min psi req'd} = 10.2 \text{ psi}$$

$$\text{MIN CLAMPING FORCE} > 10.2 \text{ psi} \times A = 8,000 \#$$

$$\begin{aligned} \text{EACH } 3/8" \phi \text{ ROD} &= 2376 \# / \text{ROD} \\ \frac{8000 \#}{2376} &= 3.4 \text{ min USE 4 min. RODS.} \end{aligned}$$

CONVERT TORQUE TO CLAMPING FORCE

$$3/8" \phi \quad 16 \text{ THREADS / IN} \\ \text{SINGLE THREADED.}$$

$$\text{PITCH} = \frac{1}{16} = 0.063$$

$$\text{LEAD} = L = 1 \times \text{PITCH} = 0.063$$

$$\text{COEFFICIENT BETWEEN THREADS} = \mu_s = 0.30$$

$$\text{LEAD } \theta \quad \tan \theta = \frac{L}{2\pi r} = \frac{0.063 \text{ in}}{2\pi (3/16)} = 0.053 \quad \theta = 3^\circ$$

$$\tan \phi_s = \mu_s = 0.30 = \phi_s = 16.7^\circ$$

$$\begin{aligned} \text{FORCE } Q \\ Q(3/16 \text{ in}) &= 30 \# \text{-FT.} \\ Q &= \frac{30 \times 12}{3/16} = 1920 \# \end{aligned}$$

$$W = \frac{Q}{\tan(\phi + \phi_s)} = \frac{1920 \#}{\tan 19.7^\circ} = 5362 \#$$

$$\text{REDUCE TORQUE TO } \frac{2376 \#}{5362 \#} \times 30 \# \text{-FT.} = 13 \# \text{-FT.}$$

SEE
→
DIAGRAM